

CITY OF WILDWOOD

**Invitation To Bid
No. 2024-24**



**CR 501 WTP IRON FILTER IMPROVEMENTS
ADDENDUM NO.1**

DATE: May 24, 2024 Project Number: 142173320

This addendum forms a part of the Specifications and modifies the original Document as noted. Acknowledge receipt of this Addendum in the appropriate portion of Section 00300 with the submitted bid. Failure to do so may subject the proposer to disqualification.

1. I received a question from our manufacturer on the filter design. Can you please confirm the backwash water temperature?

Response: 77 Degrees Fahrenheit

2. Can you add Lutz-Jesco be4 named as an approved manufacturer of the chemical feed pump and skid called out in Section 11552 Paragraph 1.02 "A" numbers 1 & 2?

Response: No, the above-referenced product cannot be considered an approved equal.

3. Can Guardian Equipment be considered an approved supplier for specification 11552?

Response: Guardian Equipment will be considered an approved equal supplier.

ATTACHMENTS:

END OF SECTION